



BIDS AND AWARDS COMMITTEE

Bid Bulletin No. 01

PG-GS2019-04

Supply, Delivery, Installation, Testing and Commissioning of Two (2) Brand New Airconditioning Units for OSHC Auditorium

This Bid Bulletin is being issued to amend the following sections of the Bidding Documents of the above stated project.

| REFERENCE | AMENDMENTS / CLARIFICATIONS |
|---|---|
| <p>Section III. Bid Data Sheet, ITB Clause 29.2 List of licenses and permits relevant to the Project and the corresponding law requiring it.</p> <ol style="list-style-type: none"> 1. Latest income and business tax returns filed and paid through the BIR Electronic Filing and Payment System (eFPS) 2. PCAB License | <p>Latest income and business tax returns should cover the period from July to December 2018</p> <p>PCAB License with Allowable Range of Contract Cost equivalent to Approved Budget for the Contract (Size Range <u>Small B</u> – with specialty in Air-conditioning or Refrigeration)</p> |
| <p>Section III. Bid Data Sheet, ITB Clause 12.1(a)(ii), The bidder's SLCC similar to the contract to be bid should have been completed within two (2) years prior to the deadline for the submission and receipt of bids.</p> | <p><u>Completion date</u> must be within the last two (2) years from the deadline of submission of bids.</p> |

| Section VI. Technical Specifications | | Section VI. Technical Specifications | |
|--|--|---|--|
| Item | Specification | Item | Specification |
| 1 | <p>Two (2) units 30-Toner Airconditioner 220 V, 3 Phase, 60Hz</p> <p>Working Fluid: Not listed in Montreal Protocol for phase-out of Ozone Depleting Substances (ODS).</p> <p>Indoor Unit:</p> <ul style="list-style-type: none"> ✓ Duct type Floor mounted. ✓ Airflow > 8300 CFM/unit ✓ Up blast discharge opening <p>Outdoor Unit:</p> <ul style="list-style-type: none"> ✓ Air Cooled ✓ Up blast discharge opening <p>Compressor:</p> <ul style="list-style-type: none"> ✓ Hermetic Scroll ✓ Non inverter type model | 1 | <p>Two (2) units 30-Toner Airconditioner 220 V, 3 Phase, 60Hz</p> <p>Working Fluid: Not listed in Montreal Protocol for phase-out of Ozone Depleting Substances (ODS).</p> <p>Indoor Unit:</p> <ul style="list-style-type: none"> ✓ Duct type Floor mounted. ✓ Airflow > 8300 CFM/unit ✓ <u>Static Pressure = 50 mm Hg</u> ✓ Up blast discharge opening <p>Outdoor Unit:</p> <ul style="list-style-type: none"> ✓ Air Cooled ✓ Up blast discharge opening <p>Compressor:</p> <ul style="list-style-type: none"> ✓ Hermetic Scroll ✓ <u>Inverter type model</u> |
| | <p>Delivery period: Thirty (30) calendar days after receipt of Notice to Proceed (NTP)</p> | | <p>Delivery period: <u>Ninety (90) calendar days</u> after receipt of Notice to Proceed (NTP)</p> |
| 2 | <p>Unit Warranty Coverage</p> <ul style="list-style-type: none"> a. Compressor minimum of five (5) years b. Parts minimum of two (2) years | 2 | <p>Unit Warranty Coverage</p> <ul style="list-style-type: none"> a. Compressor minimum of five (5) years b. Parts minimum of <u>one (1) year</u> |
| <p>Deadline of Submission and Opening of Bids:</p> <p>April 24, 2019, 2:00 P.M.</p> | | <p>Deadline of Submission and Opening of Bids:</p> <p><u>April 29, 2019, 11:00 A.M.</u></p> | |

For information of all concerned.



ENGR. JOSE MARIA S. BATINO, CESO IV
Chairman, Bids and Awards Committee